

# KEYNOTES:

  
 DCN CNMS-01

**N014** RECEPTACLE IS RESERVED FOR PUMP SKID INDICATED.

**N015** PROVIDE 120V TO DOOR 24 VDC POWER SUPPLY FROM CN-2PPB-1 CKT #1. SEE DETAIL 10, SHEET E8.11.42.

**N016** PROVIDE 120V EMERG POWER FROM CN-2EPPC-1, CKT #8 TO JB IN RM B1-7-2. HARDWIRE FROM JB TO EACH OF 5 DDC'S PROVIDED BY MECH. SEE DWG H2.B1.67.

**N017** PROVIDE 120V EMERG POWER FROM CN-2EPPC-1, CKTS #10, 12 TO CONTROL CONSOLE PROVIDED BY MECH IN ROOM B1-7-11. SEE DWG H2.B1.67.

  
 DCN CNMS-01

**N018** PROVIDE 120V EMERG POWER FROM CN-2EPPC-1, CKT #17 TO JB IN RM B1-7-2. HARDWIRE FROM JB TO PROCESS COOLING WATER EMERG CITY WATER FLUSH SOLENOIDS PROVIDED BY MECH. SEE MECH DWGS.